

Project Review:

SC2001-09

Seven Greens: 120 residential units on 58 acres

Project Location:

MAP: 9

Plymouth

NE quad Vicksburg La and Schmidt Lake Rd

3 Ponds: SE corner of dev discharges to wetland mitigation; NW interior 2 cell discharges to wetland; NE corner next to RR (path through wetland?)

Inlet (s): There are two inlets; they are stabilized with riprap and clear of debris.

Outlet(s): The outlet structure is clear of debris and skimming has been provided.

Basin(s): A permanent pool is provided with average depths of 3 to 4.5 feet. Side slopes are vegetated. There is still silt fence around the basin. It should be removed.

There is debris in the emergency spillway, which needs to be removed.

Inspection Date: October 12, 2004

Comments: Only one pond in the southeast corner has been installed as of the date of this review.

Remove silt fence around the constructed basin. Remove debris in emergency overflow of constructed basin.

