

**Project Review:** SC2002-01  
France Avenue Relocation Project

**Project Location:** MAP: 1  
Brooklyn Center  
Azelia Avenue N./ 50th Avenue North  
Wetland Replacement/ Mitigation, stormwater pond: 1 pond, one upland buffer, one created wetland

**Inlet (s):** OK, stabilized with riprap and well vegetated.

**Outlet(s):** OK, stabilized with riprap. Skimming provided with baffled weir.

**Basin(s):** OK, side slopes are well vegetated and stabilized. Permanent pool of 2-5'.

**Inspection Date:** August 24, 2005

**Comments:** No recommended pond improvements.  
Annual wetland mitigation monitoring report should be submitted to LGU.

