

Project Review: SC2002-04
Upsher-Smith Corporate Campus:

Project Location: MAP: 2
Maple Grove
(T199 R22 S34 Northeast qtr) I-494 between Bass Lake Rd and East Fish Lake Rd (off Sycamore Lane -new road)

2 ponds: Pond A & B. Both are permanent pools on the south western portion of the site. Created wetland and upland buffers around the wetland as well as buckthorn removal on the southwest portion of site.

Inlet (s): The inlets are stabilized with riprap and they are clear of debris. No maintenance is required at this time.

Outlet(s): The outlet is clear of debris. Skimming appears to be provided but at this time, due to low water, there is no skimming. An outlet control structure could not be located.

Basin(s): There is a permanent pool provided with an estimated average depth of 4 feet. The side slopes are vegetated with cattails and reeds. No maintenance is required at this time.

Inspection Date: October 6, 2004

Comments: No recommended improvements.

