

Project Review:

SC2002-13

Hidden Terrace, Residential Homes

Project Location:

MAP:

9

Plymouth

E of Fernbrook Ln, N of Rockford Rd, W of I494

Rain garden and pond: RG discharges to pond which discharges to wetland to E

Inlet (s): The inlets are stabilized with riprap and clear of debris.

Outlet(s): The outlet is a beehive frame and grate at the bottom of a secondary pond. There is an armored spillway and it is stabilized.

Basin(s): The pond has a permanent pool with estimated depth of 1 to 2 feet and a wetland. The side slopes are vegetated. No maintenance is required at this time.

Inspection Date: October 12, 2004

Comments: No recommended improvements.

