

Project Review:

SC2003-07

Kylawn Park Drainage Improvements

Project Location:

MAP:

7

Brooklyn Center

Western corner Kylawn Park, SE quad 61st & Lee

Add 15" outlet pipe (w of tennis ct) to drain landlocked depression to south

Inlet (s): OK, inlets are stabilized with riprap.

Outlet(s): Drainage route from outlet pipe not clearly defined.

Basin(s): OK

Inspection Date: October 14, 2004

Comments: Confirm that overland drainage route from new pipe was graded correctly.



Inlet pipe looking northwest



Inlet pipe looking south